



Carbon Monoxide (CO) Detector Certification

Property Owner's Name: _____

Property Address: _____ Block ____ Lot ____

Homeowner

- () I have reviewed the required locations of Carbon Monoxide (CO) Detectors below and my home already complies with the requirements.
- () I have reviewed the required locations of Carbon Monoxide (CO) Detectors below and will install the required detectors prior to calling for final inspections.

Homeowner Signature: _____ Date: _____

Contractor/Agent

- () I will advise the homeowner of the requirements for Carbon Monoxide (CO) Detectors and provide them with the bottom of this form for their review. I Certify that prior to completion of this project I will assure compliance with the regulations.

Contractor/Agent: _____ Date: _____

Borough of New Providence Code Enforcement

Dear Homeowner,

New Jersey State Law now required that any existing dwelling, that contains a fuel burning appliance, fireplace, woodstove, or having an attached garage, that undergo a repair, renovation, alteration, addition or installation of equipment that requires a permit, be equipped with a Carbon Monoxide (CO) detector. No additional permit is required for their installation, unless they are permanently connected to the homes electrical wiring. These detectors are available from most hardware stores, home centers, department stores and discount stores. These detectors are available from approx. \$20.00 - \$100.00 and combination Smoke/CO detectors are available form approx. \$50.00 - \$80.00. These detectors may be battery operated plug-in or hard wired w/battery back-up. These detectors must be installed (if not already) before calling for final inspections. NOTE: Bedrooms being altered, renovated or newly created bedrooms have additional smoke detector requirements.

Carbon Monoxide (CO) Detector Locations

CO Detectors should be located outside each separate sleeping area in the vicinity of the bedrooms as shown in Figure 1, Figure 2, Figure 3, and Figure 4 on the back of this page. All CO detectors should be installed in accordance with the manufacturer's installation instructions. All CO Detectors should be located and mounted so that jarring or vibration will not cause accidental operation. All CO Detectors should be supported independently of their attachment to wire.