

RESOLUTION
of the
BOROUGH OF NEW PROVIDENCE
Resolution No. 2015-209

Council Meeting Date: 05-18-2015

Date Adopted: 05-18-2015

TITLE: RESOLUTION APPROVING PURCHASE ORDER FOR RAPID PUMP & METER SERVICE CO., INC., IN THE AMOUNT NOT TO EXCEED \$6,500.00, FOR EMERGENCY PUMP REPAIRS

Councilperson Muñoz submitted the following resolution, which was duly seconded by Councilperson Galluccio.

BE IT RESOLVED by the Mayor and Council of the Borough of New Providence, in the County of Union and State of New Jersey, that they do hereby approve purchase as follows:

Capital	-	15-263-930-3-40040
Amount Not to Exceed	-	\$ 6,500.00

Said purchase order is made and approved in the form as attached hereto and made a part thereof. Funds for said purchase order are certified available from Current Budgeted Appropriations.

APPROVED, this 18th day of May, 2015.

RECORD OF VOTE

	AYE	NAY	ABSENT	NOT VOTING
GALLUCCIO	X			
GENNARO			X	
KAPNER	X			
MADDEN	X			
MUÑOZ	X			
ROBINSON	X			
MORGAN			TO BREAK COUNCIL TIE VOTE	

I hereby certify that the above resolution was adopted at a meeting of the Borough Council held on the 18th day of May, 2015.

Wendi B. Barry, Borough Clerk



BOROUGH OF
NEW PROVIDENCE
SETTLED IN 1720

WASTEWATER TREATMENT PLANT
10 PARK PLACE
NEW PROVIDENCE NJ 07974

MEMORANDUM TO: Douglas Marvin, Borough Administrator

FROM: Anthony Carnevale Jr., Supervisor, Licensed Plant Operator

SUBJECT: Recirculation Pump Replacement

DATE: May 14, 2015

The treatment plants two (2) recirculation pumps are located in an underground tank located between the rock filter and final clarifier. These pumps are always submerged under wastewater and their function is to take rock Filter flow and return it back to the head box of the primary tank to be reprocessed. These pumps have to lift the flow about 20' feet to the primary tank.

New recirculation pumps were installed during the 1995 plant upgrade. These pumps have been repaired and rebuilt numerous times by our department. In July 2012 pump #2 went out on a seal failure. The parts to repair the pump were about \$2500.00 dollars and it was determined at that time due to the pumps age and cost of repairs it wouldn't be a cost effective solution to repair the pump anymore. The pump was replaced at that time. We wanted to replace the pumps with the exact EMU Davis pumps that were installed but EMU Davis was bought out by WILO Pumps. We purchased a Wilo Pump as the replacement pump.

We have the same scenario currently with Pump #1 and need to get it replaced ASAP. We really can't wait for this to go on the council agenda because we are relying solely on Pump #2. If pump #2 were to fail we would lose all recirculation capabilities. So this should be treated as an emergency.

The two local suppliers of these pumps are Rapid Meter and Pumps and G.P. Jager Associates. I have received quotes from both suppliers. Rapid Meter & Pumps price of five thousand seven hundred and eighty five dollars (\$5785.00) is the lowest price. Funds for this purchase can be taken out of the department's capital account # 15-263-930-3-40040 (Acquisition of Equipment).

There is a lead time to acquire this pump so your quick response to this matter is greatly appreciated.

Thank You

A handwritten signature in black ink, appearing to read "Anthony Carnevale". The signature is fluid and cursive, with the first name "Anthony" and last name "Carnevale" clearly distinguishable.

Anthony Carnevale

Cc: Councilman Robinson