

RESOLUTION
of the
BOROUGH OF NEW PROVIDENCE
Resolution No. 2017-263

Council Meeting Date: 10-23-2017

Date Adopted: 10-23-2017

TITLE: RESOLUTION APPROVING PURCHASE ORDER NO. 17-01830 FOR RAPID PUMP & METER SERVICE CO., INC., IN THE AMOUNT NOT TO EXCEED \$7,000.00, FOR EMERGENCY PUMP REPAIRS

Councilperson Madden submitted the following resolution, which was duly seconded by Councilperson Muñoz.

BE IT RESOLVED by the Mayor and Council of the Borough of New Providence, in the County of Union and State of New Jersey, that they do hereby approve purchase as follows:

Purchase Order #	-	17-01830
Capital	-	C-04-55-973-455-306400
Amount Not to Exceed	-	\$ 7,000.00

Said purchase order is made and approved in the form as attached hereto and made a part thereof. Funds for said purchase order are certified available from Current Budgeted Appropriations.

APPROVED, this 23rd day of October, 2017.

RECORD OF VOTE

	AYE	NAY	ABSENT	NOT VOTING
GALLUCCIO	X			
GENNARO	X			
KAPNER	X			
MADDEN	X			
MUÑOZ	X			
ROBINSON	X			
MORGAN			TO BREAK COUNCIL TIE VOTE	

I hereby certify that the above resolution was adopted at a meeting of the Borough Council held on the 23rd day of October, 2017.

Wendi B. Barry, Borough Clerk



BOROUGH OF
NEW PROVIDENCE
SETTLED IN 1720

WASTEWATER TREATMENT PLANT
10 PARK PLACE
NEW PROVIDENCE NJ 07974

MEMORANDUM TO: Douglas R. Marvin, Borough Administrator

CC: Wendi Barry,

FROM: Anthony Carnevale Jr., Superintendent, Wastewater Operations

SUBJECT: Emergency Summit Force main Valve

DATE: October 20, 2017

The Summit pump # 2 discharge valve was closed to repack the pump. When trying to open the valve to put the pump back online the valve is stuck in the closed position. We exhausted all known ways of unlocking the valve but were unsuccessful. I needed to call in Rapid Meter and Pumps to replace this 8" inch gate valve as an emergency repair.

Currently Summit pump #1 is being overhauled and is out of operation for the next few days. The current situation has left us without either of our 2 MGD force main pumps.

I will look to replace the other discharge gate valve on Summit pump #1 as both of these valves were installed in the 1970's and have become problematic to open and close for pump maintenance.

Requisition # R1701945 in the amount of \$7000.00 dollars has been created for this emergency repair.

Purchase No: 17-01830

Status: Open

Order Date: 10/20/17

Due Date:

Description: Service call

P.O. Total: 7,000.00

Void Total: 0.00

Vendor: RAPID005

RAPID PUMP & METER SERVICE CO.

PO BOX AY

PATERSON NJ 07509

Seq	Catalog Num	Qty	Unit	Price	Item Total	Stat/Chk	Enc Date	Rcvd Date	Chk/Void Date	Invoice
	Line Item Descript					Charge Acct			Charge Acct	Description
	Line Item Notes									
1	Service call	1.0000		7,000.0000	7,000.00	0 0	10/20/17			
	Emergency service call to check summit pump valve estimated					C-04-55-973-455-306400			WWTP-REPLACE PUMPS, VALVES. CONTROLS	
					7,000.00					