

RESOLUTION
of the
BOROUGH OF NEW PROVIDENCE
Resolution No. 2018-107

Council Meeting Date: 04-09-2018

Date Adopted: 04-09-2018

TITLE RESOLUTION AWARDDING CONTRACT GP JAGER INC FOR
WASTEWATER TREATMENT FACILITY REPLACEMENT EQUIPMENT

Councilperson Madden submitted the following resolution, which was duly seconded by Councilperson Geoffroy.

WHEREAS, the Borough of New Providence has a need to acquire wastewater treatment facility replacement equipment as an “extraordinary unspecifiable service” pursuant to the provisions of N.J.S.A. 40A11-5(1)(a)(ii) and N.J.A.C. 5:34-2; and

WHEREAS, the Interim CFO has determined and certified in writing that the value of the service will exceed \$17,500; and

WHEREAS, the anticipated term of this contract is one (1) year; and

WHEREAS, GP Jager Inc., has submitted a proposal dated February 20, 2018, indicating they will provide the replacement/exchange grinder equipment for the Wastewater Treatment Facility for an amount not to exceed \$23,709.48 and

WHEREAS, GP Jager, Inc. has completed and submitted a Business Entity Disclosure Certificate which certifies that GP Jager, Inc. has not made any reportable contributions to a political or candidate committee in the Borough of New Providence in the previous one year, and that the contract will prohibit GP Jager, Inc. from making any reportable contributions through the term of the contract, and

WHEREAS, the maximum amount of the contract is not to exceed \$23,709.48, and said funds are available from the following account:

C-04-55-973-455-306400

and have been certified by the Chief Financial Officer; and

WHEREAS, the Local Public Contracts Law (N.J.S.A. 40A:11-5) requires that the resolution authorizing and awarding of contracts for “extraordinary unspecifiable service” without competitive bids and the contract itself must be available for public inspection.

NOW, THEREFORE, BE IT RESOLVED by the Mayor and Council of the Borough of New Providence that they hereby agree as follows:

1. The Mayor and Borough Clerk are hereby authorized and directed to execute the attached agreement with GP Jager, Inc. – sole New Jersey provider for JWC equipment.
 2. Such contract is awarded without competitive bids as a “extraordinary unspecifiable service” in accordance with N.J.S.A. 40A11-5(1)(a)(ii) of the Local Public Contracts Law, because the services to be rendered are specialized and qualitative in nature and can only be provided by the original manufacturer of the equipment.
 3. A notice of this action shall be published once in the Courier News
- APPROVED, this 9th day of April, 2018.

RECORD OF VOTE

	AYE	NAY	ABSENT	NOT VOTING
GENNARO	X			
GEOFFROY	X			
KAPNER	X			
MADDEN	X			
MUÑOZ	X			
ROBINSON	X			
MORGAN			TO BREAK COUNCIL TIE VOTE	

I hereby certify that the above resolution was adopted at a meeting of the Borough Council held on the 9th day of April, 2018.

Wendi B. Barry, Borough Clerk

STANDARD CERTIFICATION DECLARATION FOR AN EXTRAORDINARY
UNSPECIFIABLE SERVICE

TO: Mayor Morgan and Members of Borough Council
FROM: Ronald J. Angelo, Interim CFO
DATE: April 3, 2018
SUBJECT: Replacement/Exchange of the Grinder at the Wastewater Treatment Plant

This is to request your approval of a resolution authorizing a contract to be executed as follows:

Firm: GP Jager Inc – JWC's Sole provider for New Jersey

Cost: \$23,709.48


Duration: 3 to 4 Years

Purpose: Replacement/Exchange of the Grinder at the Wastewater Treatment Plant due to normal wear and tear. The cutting teeth on the unit have dulled and the grinder is allowing partially cut debris to pass into the system causing the pumps to clog.

This is to request an award of a contract without the receipt of formal bids as an Extraordinary Unspecifiable Service [N.J.S.A. 40A:11-5(1)(a)(ii) and N.J.A.C. 5:34-2.3(b)]. I do hereby certify to the following:

1. Provide a clear description of the nature of the work to be done.
To Replace/Exchange one of the Grinders at the Wastewater Treatment Plant.
2. Describe in detail why the contract meets the provisions of the statute and rules:
Specific grinder can only be supplied by JWC.
3. The service(s) is of such a specialized and qualitative nature that the performance of the service(s) cannot be reasonably described by written specifications because:
This existing Grinder and all its parts are exclusively manufactured by JWC.
4. Describe the informal solicitation of quotations:
Aqua Solutions, Middleboro, MA..... \$25,740.00
Das Group, Inc, Pittsburgh, PA.....\$29,145.75
GP Jager Inc, Booton, NJ.....\$23,709.48
5. I have reviewed the rules of the Division of Local Government Services pursuant to N.J.A.C. 5:34-2.1 et seq. and certify that the proposed contract may be considered an extraordinary unspecifiable service in accordance with the requirements thereof.

Respectfully,



Ronald J. Angelo
Interim CFO

(Original to be retained by governing body's Clerk with the affirmed copy of the resolution; signed duplicate to be kept by appropriate official.)

GP Jager Inc.

P.O. Box 50
 Boonton, N.J. 07005
 phone: (973) 750-1180
 fax: (973) 750-1181
 email: jsanz@jagerinc.com
 website: www.jagerinc.com

PAGE: 1

DATE: 2/20/2018

BID DATE:

JOB NUMBER: 967-8 REV

Water & Wastewater Representatives for the Tri-State Area

ADDRESS TO:

Borough of New Providence
 360 Elkwood Ave
 New Providence, NJ 07974
 Attn: Anthony Carnevale
 Tel: 908-665-1077
 acarnevale@newprov.org

PROJECT NAME:

JWC

GRINDER SN: G009545-2-1

Quoted by Janelle Sanz

CREDIT TERMS: NET 30 DAYS

SPEC SECTION

FREIGHT: INCLUDED

DELIVERY 4-6 WEEKS ARO

EST SHIP WT:

LN	QTY	UM	DESCRIPTION/PART NUMBER	UNIT PRICE	EXT. PRICE
A	1	EA	EVAL_CA CMD2410-XDS2.0 Grinder SN: G009545-2-1	\$0.00	\$0.00
B	1	EA	CMD2410-XDS2.0 WR Upgrade 17T Serrated Cam Cutters with Knurled Spacers 1:1 Stack Hardened Alloy STL Buna N Elastomers Cork & Rubber Gaskets Delta P Side Rails Drilled End Housings for Guide Plate Adapter Motor Type: Hydraulic New TRQ Motor New Spool 12 mm (1/2") Perforated Drum with Drum Brush Grinder SN: TBD Wipes Ready Monster Upgrade includes: Patented 17T Wipes Ready Cutters and Spacers for 2D Cutting Patented Optimized Cut Control Gearing Patented Delta P Side Rails Patented 12mm (1/2in) Perforated Drum	\$23,709.48	\$23,709.48
C	2	EA	O&M MANUALS	\$0.00	\$0.00

Please address your purchase order to:
 GP Jager Inc
 PO BOX 50
 Boonton, NJ 07005
 Fed ID: 46-3762691



Middleboro, MA
 508-947-5777
 508-861-0733 Fax

Portland, ME
 207-828-5559
 207-871-5972 Fax

Watertown, MA
 617- 923-3900
 617-249-0634 Fax

QUOTATION #WLB2018-03-28
Borough of New Providence NJ
Channel Monster

QUOTE DATE: March 28, 2018

TERMS: Net 30 days

PRICING: Valid for 90 days

SHIP EQUIPMENT: 4 - 6 weeks after release

FREIGHT: Included

We thank you for your inquiry and are pleased to quote pricing and delivery on the equipment listed below.

Item #	Description	Qty	Unit Price	Extended Price	Delivery
1	Channel Monster Model: CMD2410-XDS2.0 Channel Monster® Wipes Ready Upgrade 17t Serrated Cam Cutters with Knurled Spacers 1:1 Stack Hardened Alloy STL Buna N Elastomers/Cork & Rubber Gaskets Delta P Side Rails Drilled End Housings for Guide Plate Adapter Motor; Hydraulic New torque motor New Spool 12mm Peforated Drum with Drum brush Grinder serial number G009545-2-1	1	\$25,740.00	\$25,740.00	
2	O & M Manuals	1	\$0	\$0	
			Total	\$25,740.00	

3251-C Old Frankstown Road
Pittsburgh, PA 15239

DAS GROUP, INC.

Phone: 724-327-8979
Fax: 724-733-9066

www.dasgroupinc.com



info@dasgroupinc.com

Prepared By: Dan Nelson

Mobile: 412-559-8646

dan@dasgroupinc.com

Estimate #: 18-0113

Date: Mar 27, 2018

Engineer:

Bid Date:

Spec. Section:

Lead Time:

To: Borough of New Providence

Attention: Anthony Carnevale

360 Elkwood Ave
New Providence, NJ 07974

Email: acarnevale@newprov.org

Fax:

Project:

Misc: JWC CMD Upgrade

DAS Group • Estimate 18-0113 •

Line Item	Qty.	Equipment - Description - Details
1	1	<p>JWC Model CMD2410 Channel Monster™ Exchange Repair with "Wipes Ready" Technology Scope of supply to include:</p> <p>JWC Two Shafted Grinder with 24" cutter stack, Upgraded to the "Wipes Ready" 17-tooth cam cutters in 17T alloy steel, 10" dia. 304 stainless steel rotating drum with 1/2" diameter holes on a 1/2" stagger, cartridge-style tungsten carbide mechanical seals with BUNA-N elastomers rated for 90 psi, green epoxy-coated ductile iron housings and Upgraded Delta P Siderails and Optimized Cut Gearing, Torque Motor w/ Spool Piece</p> <p>Exchange/Repair Cutter Cartridge Only</p> <p>(Existing Serial # G009545-2-1)</p> <p>Does Not Include: Control Panel</p> <p>O & M Manuals (2)</p>

Manufacturer Quote #:

Proposal Total:

\$29,145.75

"Unless specifically mentioned the above proposal does not include installation, freight, startup or any taxes."



DAS Group, Inc. "The Environmental Solutions Provider"

